

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Mohawk for Lowes Duracraft

508 East Morris Street, Dalton, Georgia 30721, United States

For the following product(s):

**Vinyl Tile:**

Lowes Duracraft Pressed Bevel, Lowes Duracraft Pressed Bevel 9x60, Lowes Duracraft Pressed Bevel On Line 9x48

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

**FloorScore®**

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-20196

Valid from: June 01, 2025 to May 31, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION BODY



A handwritten signature in black ink, appearing to read "D. Phillips".

Diana Kirsanova Phillips, Chief Assurance Officer,  
SCS Global Services