***SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:*

Neo Floor Joint Stock Company

Lot CN4.1 Minh Phuong Dinh Vu Industrial Park, Dinh Vu - Cat Hai Economic Zone, Dong Hai 2 Ward, Hai An District, Haiphong, VietNam

For the following product(s):

Vinyl Tile:
Plank and Tile Flooring with EVA underlayment, Plank and Tile Flooring with IXPE underlayment, SPC Plank and Tile Floor with Cork underlayment (*Maximum thickness: 10mm),* SPC Plank and Tile Flooring non-underlayment *(Maximum thickness: 9mm)*

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-07404

Valid from: November 01, 2025 to October 31, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services